



Specification Form Stainless DDFDC Flexible Duct Connector

DESCRIPTION

All air duct installations for heating, cooling or ventilation are attached to mechanical equipment containing a fan or blower. Vibrations, noises and rattles resulting from operation of the fan or blower are transmitted into the metal ducts which carry the noises throughout the system.

In order to isolate the vibration and noises to the source, an air-tight flexible joint, consisting of a fabric which is attached to sheet metal on both side, must be inserted between the equipment and the ductwork. This vibration isolator is called a "Flexible Duct Connector".



RELATED NFPA 90A & 90B STANDARDS

2-3.2.2 Vibration isolation connectors in duct systems shall be made of an approved flame-retardant fabric or shall consist of sleeve joints with packing of approved material, each having a maximum flame spread index of 25 and a maximum smoke developed index of 50. Exception: Approved flame-retardant fabric having a maximum length of 10 in. (45.4 cm) in the direction of airflow-NFPA No. 90A 1999

2-1.1.1 Exception No. 3: Vibration isolation connectors in duct systems shall be made of approved flame-retardant fabric or shall consist of sleeve joints with packing of approved noncombustible material. The fabric shall not exceed 10 in. (254 mm) in length in direction of airflow-NFPA No. 90B 1999

FABRIC COMPARISONS	Excelon ⁴	Neoprene	Durolon	Thermafab [®]
Continuous Temp. Range	-40°F. to 180°F.	-40°F. to 200°F.	-40°F. to 250°F.	-65°F. to 500°F.
Color	Black	Black	White	Grey
Weight Per Square Yard	22	30	26	17
Leakage Resistance ¹	350	595	250	400
Tear Strength ²	100/100	12/12	12/12	50/40
Tensile Strength ³	240/220	500/450	225/300	200/150
Base Fabric	Woven Nylon/ Polyester Blend	Woven Fiberglass	Woven Fiberglass	Woven Fiberglass
Coating	Vinyl	Neoprene	Hypalon	Silicon Rubber
Features	High Tear Strength High Abrasion Resistance	General Purpose	Excellent Ozone and Weathering Resistance Best Overall Acid Resistance	Very Low Smoke Emission High Temperature Resistance
Codes Metal-Fab 3x3x3 Grip Loc ⁺	MBXSS-100 (#10231)	MFNSS-100 (#10232)	MFDSS-100 (#10234)	
TDC/TDF 4x4x4 Grip Loc	MBX4x4x4SS-100 (#10259) MBX316SS4x4x4 (#10275)	MFN4x4x4SS-100 (#10260)	MFD316SS4x4x4 (#10276)	MFT4x4x4SS-100 (#10261)
TDC/TDF 4x6x4 Grip Loc	MBX4x6x4SS-100 (#10262)			

The stainless steel Flexible Duct Connector is manufactured by Duro Dyne with stainless steel type 304* and 316*, .015 in thickness, with a 2B finish.

*304 stainless steel: Item # 10231, 10232, 10234, 10259, 10260, 10261, 10262

*316 stainless steel: Item # 10275, 10276



Notes:

1. Leakage resistance as per Federal Test Standard 191 Method #5512. Results in P.S.I. (To convert inches of water multiply P.S.I. x 27.176.).
2. Tear strength in tongue pounds as per Federal Test Standard 191 Method #5134.1 (warp/fill).
3. Tensile strength in grab pounds as per Federal Test Standard 191 Method #5100 (warp/fill).
4. Standard Excelon is not LA city approved. Use Excelon-LA when LA city approval is necessary. (See Specification Form Excelon-LA - 203)

SUGGESTED SPECIFICATION

Vibration Isolating Flexible Duct Connector For Heating, Cooling & Exhaust Supplies & Returns.

At the inlet and discharge of all air handling equipment(unless otherwise noted) furnish and install vibration isolators. Vibration isolators shall be a coated woven fabric named _____ and shall be "Underwriters Laboratories Classified".

Vibration isolators shall have a tear strength of not less than _____, an abrasion resistance of not less than _____, and a continuous temperature range of _____. Vibration isolators shall be preassembled metal to exposed fabric to metal. Fabric and metal shall be joined by means of a double lock seam.


Vibration isolators shall be code _____ (called Flexible Duct Connectors) as manufactured by Duro Dyne Corporation, Bay Shore, N.Y.



Specifications

All Listed Duro Dyne Flexible Duct Connector Fabrics are designed to meet the following specifications:

1. MIL-C-20696B Para. 4.4.3. (Oil Resistance).
2. MIL-C-20696B Para. 4.4.4. (Hydro Carbon Resistance).
3. NFPA 90A Installation of Air Conditioning and Ventilating Systems Para. 2-3.2.2 1999 Edition.
4. NFPA 90B Warm air heating and air conditioning systems. Para. 2-1.1.1 exc. no 3 1999 Edition.
5. NFPA701 Tests for Flame Propagation of Fabrics and film.
6. California State Fire Marshal Approved.
7. Los Angeles City Approved. (See note 1 below)
8. Denver City Approved.



CHEMICAL RESISTANCE

(X = Extremely Resistant)

(~ = Not Recommended)

(O = No Data Available)

Chemical	Excelton	Neoprene	Durolon	Thermafab	Chemical	Excelton	Neoprene	Durolon	Thermafab
Acetic Acid	~	X	X	~	Hydrofluoric Acid (100%)	~	X	X	~
Aluminum Chloride	X	X	X	X	Hydrogen Peroxide	X	~	X	X
Aluminum Sulfate	X	X	X	X	Hydrogen Sulfide	X	X	X	O
Ammonia (Anhyd)	X	X	X	X	Lactic Acid	~	X	X	O
Ammonium Hydroxide	X	X	X	X	Linseed Oil	~	X	X	X
Ammonium Sulfate	X	X	X	X	Magnesium Chloride	~	X	X	~
Barium Sulfide	X	X	X	O	Maleic Acid	X	~	X	X
Black Sulfate Liquor	X	X	X	~	Methyl Alcohol	~	X	X	~
Boric Acid	X	X	X	X	Methyl Cellosolve	~	X	X	~
Butyl Alcohol	~	X	X	~	Mineral Oil	X	X	X	~
Cadmium Plating Solution	X	~	~	O	Naptha	~	~	~	X
Calcium Chloride	X	X	X	X	Nickel Chloride	X	X	X	O
Calcium Hypochlorite	X	~	X	O	Nickel Sulfate	X	X	X	X
Chlorine Water	X	~	~	~	Nitric Acid (40%)	X	~	X	~
Chromic Acid	X	~	X	O	Oleic Acid	X	~	~	~
Chromium Plating Solution	X	O	O	O	Oleum	~	~	X	O
Citric Acid	X	X	X	X	Oxalic Acid	X	X	X	X
Copper Chloride	X	X	X	O	Phosphoric Acid (85%)	~	X	X	X
Copper Sulfate	X	X	X	O	Pickling Solution	X	~	X	O
Cottonseed Oil	X	X	X	X	Potassium Chloride	X	X	X	O
Diacetone Alcohol	~	X	X	O	Potassium Cyanide	X	X	X	O
Disodium Phosphate	X	~	~	O	Potassium Dichromate	X	X	X	O
Ethyl Alcohol	~	X	X	~	Potassium Hydroxide (40%)	X	X	X	X
Ethylene Glycol	~	X	X	X	Potassium Sulfate	X	X	X	O
Ferric Chloride	X	X	X	X	Propyl Alcohol	~	X	X	~
Ferric Sulfate	X	X	X	X	Sodium Chloride	X	X	X	X
Fluoroboric Acid	X	X	X	O	Sodium Hydroxide (40%)	~	X	X	X
Formaldehyde (40%)	X	X	X	O	Sodium Hypochlorite	~	~	X	~
Formic Acid	X	X	X	O	Steam	~	X	~	O
Glucose	X	X	X	X	Sulfur Dioxide (Liquid)	~	X	X	X
Glycerine	~	X	X	X	Sulfuric Acid (50%)	X	~	X	~
Heptane	~	X	X	O	Sulfuric Acid (over 50%)	~	~	X	~
Hexane	~	X	X	O	Tannic Acid	X	X	X	O
Hydrobromic Acid (40%)	~	X	X	O	Vinegar	X	X	X	X
Hydrochloric Acid (conc)	~	X	X	~					

Duro Dyne East Division, Bay Shore, NY
 Duro Dyne Midwest Division, Fairfield, OH
 Duro Dyne West Division, Santa Fe Springs, CA
 Duro Dyne Canada, Lachine, Quebec, Canada

631-249-9000 Fax: 631-249-8346
 513-870-6000 Fax: 513-870-6005
 562-926-1774 Fax: 562-926-5778
 514-422-9760 Fax: 514-636-0328

www.durodyne.com E-mail: durodyne@durodyne.com



©2012 Duro Dyne Corporation
 Printed in USA 6/12
 B001411